



Montebello Fire Department Underground Fire Sprinkler Supply & Fire Mains Plan Submittal Requirements

If the required information below is not provided on the formal plan submittal *plans will not be accepted*. Supplemental information or attachments will also not be accepted. Please check boxes to indicate information below has been noted on plans:

- Current editions of NFPA 13 & 24
- Current City of Montebello Business License Required prior to issuance of permit**
- Provide a scope describing the project and purpose
- Name of owner and occupant.
- Name, address and contact information of party submitting the plans
- Name, address, license and contact information of contractor
- Location, including street address
- Point of compass
- Scale
- Size, location and piping arrangement of fire department connections
- Fire Service Mains:**
- Size
- Length
- Location
- Weight
- Materials (**All piping and materials shall be listed for fire protection service**)
- Provide type and class of piping
- Provide method of corrosion protection (**If applicable**)
- Fittings shall be of approved type with joints and pressure class ratings compatible with pipe
- Provide detail of method of joining of pipe and fittings
- Method of restraint
- Refer to City of Montebello Municipal Code for requirements on connection to the municipal water system, cross connections
- Point of connection to city main.
- Sizes, types and locations of valves, valve indicators, regulators, meters, and valve pits.
- Fire Hydrants**
- Size and location, including size and number of outlets and whether outlets are equipped with independent gate valves.
- Method of restraint.
- Method of protection from traffic. Provide detail
- Location of city main and nearest fire hydrant
- Provide note indicating: Fire protection water shall not be engineered or designed to enter into the municipal storm drain or sanitary sewer systems without an appropriate permit.